



LISTING INFORMATION OF
**Worldwide Door Components - 20 Minute Primed Composite Fire
Door Frame**

SPEC ID: 30103

Worldwide Door Components, Inc.
5017 North Coolidge

Tampa, FL 33614

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Worldwide Door Components model J-CP-4F Primed Composite door frame is fire-rated for 20 minutes under positive pressure with hose stream. The J-CP-4F frame is a Category C - Proprietary frame.

LIMITATIONS

Maximum outer dimensions of frame:

38-1/2 in. wide x 81-1/2 in. high

Jamb Depth:

4-9/16" Minimum; 7-1/4" Maximum

Minimum wall thickness:

4-1/2 in.

Wall construction:

Permitted for installation in walls constructed of drywall/wood studs, concrete, or masonry.

Attribute	Value
Criteria	UL 10(c) (2009)
Criteria	UL 10(b) (2009)
Criteria	CAN / ULC S104 (2010)
Criteria	NFPA 252 (2012)
Criteria	UL 10(c) 2016
CSI Code	08 10 00 Doors and Frames
Fire Resistance	20 Min PP Category C Proprietary Frame
Intertek Services	Certification
Listed or Inspected	LISTED
Listing Section	CATEGORY C - PROPRIETARY FRAMES
Report Number	100719286COQ
Spec ID	30103